


Part No.	800-646-58	REV	03
Ref. Code	407		
U.O.M.	EA		
Engg. Ref.	CHILLER		

**Part Description : RELATIVE PRESSURE TRANSDUCER (-0.5 TO 10 BAR) SUCTION PR SENSOR**



00001-1

**VENDOR : PROJECT ENGINEERING. ITALY FIRENZE**  
**VENDOR CODE : TP-10FSKO**  
**MPO : 50 EACH**  
**MANUFACTURER : KELLER**  
**TYPE : PR-21MC/80407.33-10**



**RANGE : -0.5 ... 10 BAR**  
**OUTPUT : 4 .. 20mA**  
**1: GND/ OUT**  
**3: +Vcc 8 .. 28V**

ALL DIMENSION ARE IN INCHES

SHEET 1 of 1

SCALE : N.T.S

Tolerance: : Unless noted ( ± ) : fraction 1/32" ; Decimal 0.031

				WRITER	AL-ALI. HUSAIN	
				INTIATOR & VERIFIED	JESSIE	
				CHECK	AHMAD	
03	TRANSDUCER TYPE WAS PA-21MC/80407.33-10	HUSAIN	24-10-04	APPROVAL	ALI AL-DAHAN	
02	ADDED MPO	UMESH	01-02-01			
01	REVISED VENDOR CODE WAS TP-10FSK	UMESH	30-08-00	Issue Date	11-03-2000	
REV	Revision Details	Designer	Rev.Date	File Ref.	Ziicnas\Eng-Specs\800\64658	